

**SECTION 23 07 19**  
**HVAC PIPING INSULATION**  
**PART 1 - GENERAL**  
 1.1 RELATED DOCUMENTS  
 A. Drawings and General Conditions of the Contract, including General and Supplementary Conditions and Division 01 Specification Sections, apply to this Section.  
 1.2 SUMMARY  
 A. Section includes insulating the following HVAC piping systems:  
 1. Condensate drain piping, indoors.  
 2. Chilled-water and brine piping, indoors and outdoors.  
 B. Related Sections  
 1. Section 23 07 13 "Duct Insulation."  
**3 ACTION SUBMITTALS**  
 A. Product Data: For each type of product indicated, include thermal conductivity, water-vapor permeance thickness, and jackets (both factory and field applied if any).  
 B. Qualification Data: For qualified installer.  
 C. Material Test Reports: From a qualified testing agency acceptable to authorities having jurisdiction indicating, interpreting, and certifying test results for compliance of insulation materials, sealers, attachments, cements, and jackets, with requirements indicated. Include dates of tests and test methods employed.  
 D. Field quality-control reports.  
**1.5 QUALITY ASSURANCE**  
 A. Installer Qualifications: Skilled mechanics who have successfully completed an apprenticeship program or another craft training program certified by the Department of Labor, Bureau of Apprenticeship and Training.  
 B. Surface-Burning Characteristics: For insulation and related materials, as determined by testing identical products according to ASTM E 84, by a testing and inspecting agency acceptable to authorities having jurisdiction. Factory label insulation and jacket materials and adhesive, mastic, tapes, and cement material containers, with appropriate markings of applicable testing agency.  
 1. Insulation installed indoors: Flame-spread index of 25 or less, and smoke-developed index of 50 or less.  
 2. Insulation installed outdoors: Flame-spread index of 75 or less, and smoke-developed index of 150 or less.  
**1.6 DELIVERY, STORAGE, AND HANDLING**  
 A. Packaging: Insulation material containers shall be marked by manufacturer with appropriate ASTM standard designation, type and grade, and maximum use temperature.  
**1.7 COORDINATION**  
 A. Coordinate sizes and locations of supports, hangers, and insulation shields specified in Section 23 05 29 "Hangers and Supports for HVAC Piping and Equipment."  
 B. Coordinate clearance requirements with piping installer for piping insulation application. Before preparing piping Shop Drawings, establish and maintain clearance requirements for installation of insulation and field-applied jackets and finishes and for space required for maintenance.  
 C. Coordinate installation and testing of heat tracing.  
**1.8 CHEMICALS**  
 A. Schedule insulation application after pressure testing systems and, where required, after installing and testing heat tracing. Insulation application may begin on segments that have satisfactory test results.  
 B. Complete installation and concealment of plastic materials as rapidly as possible in each area of construction.  
**PART 2 - PRODUCTS**  
**2.1 INSULATION MATERIALS**  
 A. Comply with requirements in "Piping Insulation Schedule, General," "Indoor Piping Insulation Schedule," "Outdoor, Aboveground Piping Insulation Schedule," and "Outdoor, Underground Piping Insulation Schedule" articles for where insulating materials shall be applied.  
 B. Products shall not contain asbestos, lead, mercury, or mercury compounds.  
 C. Products that come in contact with stainless steel shall have a leachable chlorine content of less than 50 ppm when tested according to ASTM E 84.  
 D. Insulation materials for use on austenitic stainless steel shall be qualified as acceptable according to ASTM C 795.  
 E. Foam insulation materials shall not use CFC or HCFC blowing agents in the manufacturing process.  
 F. Calcium Silicate:  
 1. Preformed Pipe Sections: Flat, curved, and grooved-block sections of noncombustible, inorganic, hydroxyl calcium silicate with a non-asbestos fibrous reinforcement. Comply with ASTM C 1336, Type I.  
 2. Flat, curved, and grooved-block sections of noncombustible, inorganic, hydroxyl calcium silicate with a non-asbestos fibrous reinforcement. Comply with ASTM C 533, Type I.  
 3. Prefabricated Fitting Covers: Comply with ASTM C 450 and ASTM C 585 for dimensions used in preforming insulation to cover valves, elbows, tees, and flanges.  
 G. Cellular Glass: Inorganic, incombustible, foamed or cellulated glass with annealed, rigid, hermetically sealed cells. Factory-applied jacket requirements are specified in "Factory-Applied Jackets" Article.  
 1. Manufacturers: Subject to compliance with requirements, available manufacturers offering products that may be incorporated into the Work include, but are not limited to the following:  
 a. Eggsig Corp.  
 b. Block Insulation  
 c. Special-Shaped Insulation: ASTM C 552, Type III  
 d. Preformed Pipe Insulation without Jacket: Comply with ASTM C 552, Type I, Class 1.  
 e. Preformed Pipe Insulation with Factory-Applied ASJ-SSL, Comply with ASTM C 552, Type I, Class 2.  
 f. Factory fabricate shapes according to ASTM C 450 and ASTM C 585.  
 H. Flexible Elastomeric Insulation: Closed-cell, sponge or open-cell-elastomer materials. Comply with ASTM C 534, Type I for tubular materials.  
 1. Manufacturers: Subject to compliance with requirements, available manufacturers offering products that may be incorporated into the Work include, but are not limited to the following:  
 a. Armaflex USA, Inc.  
 b. Armaflex LLC  
 c. ICFO USA  
 D. Mineral-Fiber Insulation:  
 1. Manufacturers: Subject to compliance with requirements, available manufacturers offering products that may be incorporated into the Work include, but are not limited to the following:  
 a. Johns Manville, a Berkshire Hathaway company  
 b. Knaf Insulation  
 c. Margon Insulation  
 d. Owens Corning  
 2. Type I, 850 Deg F Materials: Mineral or glass fibers bonded with a thermosetting resin. Comply with ASTM C 547, Type I, Grade A, with factory-applied ASJ-SSL. Factory-applied jacket requirements are specified in "Factory-Applied Jackets" Article.  
 3. Type II, 1200 Deg F Materials: Mineral or glass fibers bonded with a thermosetting resin. Comply with ASTM C 547, Type II, Grade A, with factory-applied ASJ-SSL. Factory-applied jacket requirements are specified in "Factory-Applied Jackets" Article.  
**2.2 INSULATING CEMENTS**  
 A. Mineral-Fiber Insulating Cement: Comply with ASTM C 195.  
 1. Subject to compliance with requirements, available manufacturers offering products that may be incorporated into the Work include, but are not limited to the following:  
 a. Ramco Insulation, Inc.  
 B. Expanded or Extruded Vermiculite Insulating Cement: Comply with ASTM C 196.  
 1. Subject to compliance with requirements, available manufacturers offering products that may be incorporated into the Work include, but are not limited to the following:  
 a. Ramco Insulation, Inc.  
 C. Mineral-Fiber, Hydraulic-Setting Insulating and Finishing Cement: Comply with ASTM C 449.  
 1. Manufacturers: Subject to compliance with requirements, available manufacturers offering products that may be incorporated into the Work include, but are not limited to the following:  
 a. Ramco Insulation, Inc.  
**2.3 ADHESIVES**  
 A. Materials shall be compatible with insulation materials, jackets, and substrates and for bonding insulation to itself and to surfaces to be insulated unless otherwise indicated.  
 B. Calcium Silicate Adhesive: Fibrous, siccative-based adhesive with a service temperature range of 50 to 800 deg F.  
 1. Subject to compliance with requirements, available manufacturers offering products that may be incorporated into the Work include, but are not limited to the following:  
 a. Children Brand, H. B. Fuller Construction Products  
 b. Foster Brand, H. B. Fuller Construction Products  
 c. Mo-Exo Industries, Inc.  
 C. Cellulose Adhesive: Two-component, thermosetting urethane adhesive containing no flammable solvents, with a service temperature range of minus 100 to plus 200 deg F.  
 1. Subject to compliance with requirements, available manufacturers offering products that may be incorporated into the Work include, but are not limited to the following:  
 a. Children Brand, H. B. Fuller Construction Products  
 D. Flexible Elastomeric and Polyurethane Adhesive: Comply with MIL-A-24179A, Type I, Class 1.  
 1. Manufacturers: Subject to compliance with requirements, available manufacturers offering products that may be incorporated into the Work include, but are not limited to the following:  
 a. Aeroflex USA, Inc.  
 b. Armaflex LLC  
 c. Children Brand, H. B. Fuller Construction Products  
 E. Mineral-Fiber Adhesive: Comply with MIL-A-3319C, Class 2, Grade A.  
 1. Manufacturers: Subject to compliance with requirements, available manufacturers offering products that may be incorporated into the Work include, but are not limited to the following:  
 a. Children Brand, H. B. Fuller Construction Products  
 b. Eggsig Bridge - Margon Industries  
 c. Foster Brand, H. B. Fuller Construction Products  
 d. Mo-Exo Industries, Inc.  
 F. ASJ Adhesive: Comply with MIL-A-3319C, Class 2, Grade A for bonding insulation jacket laps seams and joints.  
 1. Manufacturers: Subject to compliance with requirements, available manufacturers offering products that may be incorporated into the Work include, but are not limited to the following:  
 a. Children Brand, H. B. Fuller Construction Products  
 b. Eggsig Bridge - Margon Industries  
 c. Foster Brand, H. B. Fuller Construction Products  
 d. Mo-Exo Industries, Inc.  
 G. PVC Jacket Adhesive: Compatible with PVC jacket.  
 1. Manufacturers: Subject to compliance with requirements, available manufacturers offering products that may be incorporated into the Work include, but are not limited to the following:  
 a. Children Brand, H. B. Fuller Construction Products  
 b. Foster Brand, H. B. Fuller Construction Products  
 c. Knaf Insulation  
 d. Owens Corning  
 2. Water-Vapor Permeance: ASTM E 906-96M, Procedure B, 0.013 perm at 43-mil dry film thickness.  
 3. Service Temperature Range: Minus 20 to plus 180 deg F.  
 4. Solids Content: ASTM D 1644, 44 percent by volume and 70 percent by weight.  
 5. Color: White.  
 C. Vapor-Barrier Mastic: Solvent based, suitable for indoor use on below-ambient services.  
 1. Manufacturers: Subject to compliance with requirements, available manufacturers offering products that may be incorporated into the Work include, but are not limited to the following:  
 a. Children Brand, H. B. Fuller Construction Products  
 b. Eggsig Bridge - Margon Industries  
 c. Foster Brand, H. B. Fuller Construction Products  
 d. Mo-Exo Industries, Inc.  
 2. Water-Vapor Permeance: ASTM F 1249, 0.05 perm at 35-mil dry film thickness.  
 3. Service Temperature Range: 0 to 180 deg F.  
 4. Solids Content: ASTM D 1644, 44 percent by volume and 62 percent by weight.  
 5. Color: White.  
 D. Vapor-Barrier Mastic: Solvent based, suitable for outdoor use on below-ambient services.  
 1. Manufacturers: Subject to compliance with requirements, available manufacturers offering products that may be incorporated into the Work include, but are not limited to the following:  
 a. Children Brand, H. B. Fuller Construction Products  
 b. Eggsig Bridge - Margon Industries  
 c. Foster Brand, H. B. Fuller Construction Products  
 d. Mo-Exo Industries, Inc.  
 2. Water-Vapor Permeance: ASTM F 1249, 0.05 perm at 30-mil dry film thickness.  
 3. Service Temperature Range: Minus 40 to plus 220 deg F.  
 4. Solids Content: ASTM D 1644, 30 percent by volume and 46 percent by weight.  
 5. Color: White.  
 E. Breather Mastic: Water based, suitable for indoor and outdoor use on above-ambient services.  
 1. Manufacturers: Subject to compliance with requirements, available manufacturers offering products that may be incorporated into the Work include, but are not limited to the following:  
 a. Children Brand, H. B. Fuller Construction Products  
 b. Eggsig Bridge - Margon Industries  
 c. Foster Brand, H. B. Fuller Construction Products  
 d. Mo-Exo Industries, Inc.  
 2. Water-Vapor Permeance: ASTM F 1249, 1.8 perms at 0.0025-inch dry film thickness.  
 3. Service Temperature Range: Minus 20 to plus 180 deg F.  
 4. Solids Content: 60 percent by volume and 66 percent by weight.  
 5. Color: White.

# CRAIG GAULDEN DAVIS

● Architecture  
 Planning  
 Interiors

19 Washington Park  
 Greenville, SC 29601

Phone 864.242.0761  
 Fax 864.501.9945  
 E-mail cgd@gcjdarch.com

---

COPYRIGHT © 2020 CAVINESS LAMBERT ENGINEERING, LLC ALL RIGHTS RESERVED

THIS COPYRIGHTED DOCUMENT AND ALL INFORMATION CONTAINED HEREIN IS AN INSTRUMENT OF SERVICE AND SHALL NOT BE REPRODUCED, ALTERED, OR REUSED IN PART OR IN WHOLE WITHOUT PRIOR WRITTEN PERMISSION FROM THE ENGINEER. DRAWING IS THE EXCLUSIVE PROPERTY OF THE ENGINEER AND MUST BE RETURNED UPON REQUEST.

**CAVINESS  
LAMBERT  
ENGINEERING**

MECHANICAL/ELECTRICAL/PLUMBING  
 508 East North Street  
 Greenville, SC 29601

---

**Greenville  
Technical College**

---

## GREENVILLE - BLDG. 112 AIR COOLED CHILLER ADDITION

**Project No. : H59-N054-FW**

DATE	MARK	DESCRIPTION
2/26/2021	D	ADDENDUM NO. 1

---

ISSUE	CONSTRUCTION
DATE:	1/15/2021
PROJECT NO:	120047-015
DRAWN BY:	CTL
CHECKED BY:	JAC

---

## MECHANICAL SPECIFICATIONS

# MP005

C:\Users\caviness\Documents\GTC Bldg 112 MEP20\_Caviness\ Lambert1.rvt 2/26/2021 11:58:09 AM